



GLB Wall Mounted Charging Station Fixed Lead

Type
GLB-T222FC

Fixed Cable

5 Meter length cable
c/w T2 Plug

Rated current [A]
6, 10, 16, 20, 25, 32.

Power outlet [kW]
3.7KW, 7.4KW, 22KW

Load Balance
Available with
GNM3D-RS485

Meter
No.

Communication No.
RCCB/RCBO
No

DC Monitoring

No.

RFID
No.

Common characteristics

Rated voltage [V AC]

230/400

Frequency [Hz]

50

Temperature range [C]

-25...+40

Location

Wall mounted or GLB Stand.

Charge Current (A)

6, 10, 16, 20, 25, 32,

Degree of protection [IP]

44

Standard

EN 61851-1 IEC 61439-7 AEVCS

Width [mm]

205

Height [mm]

422

Depth [mm]

124

Netweight [kg]



3.20

Materials

Plastic

Colour

Black





Dokument/document	Utgåva datum/edition date	
Försäkran om överensstämmelse/ Declaration of conformity	2015-05-04	
Avdelning/department		
Kvalitet/Quality		
Ansvarig/prepared	Version	Sida/page
Kent Andersson	4	1 av/of 1

Manufacturer/Tillverkare: GARO AB
Box 203
S-335 25 GNOSJÖ
Sweden

Telephone: +46 (0)370 33 28 00
Telefax: +46 (0)370 33 28 50

Agent established within EC/Ombud etablerad inom EG

Telephone:
Telefax:

Agent of equipment/Materielslag: Home charger/Hemmaladdare

Trade Mark/Varumärke: GARO

Type Designation/Typbeteckning: GHL-...GLB-...and/och GHLM-...

**We hereby declare that our product fulfils the requirements of following EC directives/
Vi intygar härmed att vår produkt uppfyller krav enligt följande EU direktiv:**

- The Low Voltage Directive (LVD) 2014/35/EU / Lågspänningsdirektivet (LVD) 2014/35/EU.**
- Electromagnetic compatibility (EMC) 2014/30/EU / Elektromagnetisk kompatibilitet (EMC) 2014/30/EU.**
- RoHS Directive (RoHS) 2011/65/EU / RoHS direktivet (RoHS) 2011/65/EU.**
- No electromagnetic compatibility (EMC 2014/30/EU) immunity or emission tests are required on the assembly / Produkten innehåller inte elektroniska apparater som påverkas enligt förbehållen enligt direktivet (EMC) 2014/30/EU.**

**The following harmonised standards (latest edition) or technical specifications which comply with good engineering practice in safety matters in force within the EC have been used in the design:/
Följande harmoniserade standarder (senaste utgåva) eller tekniska specifikationer som uppfyller god säkerhetsteknik praxis inom EG har använts i konstruktionen: EN 61851-1, EN 62196-2 and/och IEC/TS 61439-7.**

- The equipment confirms completely with the above stated harmonised standards or technical specifications./
Materielen överensstämmer helt med ovan angivna harmoniserade standarder eller tekniska specifikationer.**

Or/Eller

- The equipment confirms only partially with the above stated harmonised standards or technical specifications but complies with good practice in safety matters in force within the EC./
Materielen överensstämmer endast delvis med ovan angivna harmoniserade standarder eller tekniska specifikationer, men uppfyller god säkerhetsteknisk praxis inom EG.**

We have product surveillance according to CENELEC's harmonised requirements, documents CCA-201.

GARO AB
Company/Företag

2017-11-24
Date/Datum

Sign/Underskrift

Responsible for Technology and standardization/Teknik och standardiseringsansvarig
Position/Befattning

Kent Andersson
Sign in printed letters/Namnförtydligande