

Flush Domestic Consumer Unit with Main MCB & Surge Protection

(IS 10101)

K36B-7AS



Technical data

K36B-7AS

Rated current	80A
Rated voltage	230 V AC
Frequency	50/60 Hz
Rated short-circuit capacity	10 kA
Main Device	Double Pole MCB 10KA 63A
Additional Devices	2 x RCCB & 7 x MCB
Surge Protection	Double Pole Surge Arrestor GPT300
Degree of protection	IP40
Total number of ways	42
Total Number of free ways	28
Height..mm (H)	568
Width..mm (W)	368
Depth..mm (D)	93
Ambient temperature (C)	-25.....+55
Storage temperature (C)	-35.....+55
Main Terminals	25mm LN & E
Maximum Backup Protection (A)	80A
Standard	EN 61439-3



Dokument/document Försäkran om överensstämmelse/ Declaration of conformity		Utgava datum/edition date 2018-06-14
Avdelning/department Kvalite/Quality		
Ansvarig/prepared Magnus Arvidsson	Version 3	Sida/page 1 av/of 1

Supplier/Tillverkare:

GARO AB
Box 203
S-335 25 GNOSJO
Sweden

Telephone: +46 (0)370 33 28 00

Telefax: +46 (0)370 33 28 50

Supplier established within EU/Ombud etablerad inom EG

Supplier of equipment /Materielslag : Consumer unit/Normcentral

Trade Mark/ Varumärke: GARO

Type Designation / Typbeteckning: G, K, 12,14,18, 24, 26, 36, 218, 39, I, B, C, 7, 8, 9, A, B, S,

We hereby declare that our product fulfils the requirements of following EC directives/ Vi intygar härmed att vår produkt uppfyller krav enligt följande EU direktiv:

- ☒ The Low Voltage Directive (LVD) 2014/35/EU / Lågspänningsdirektivet (LVD) 2014/35/EU.
- ☐ Electromagnetic compatibility (EMC) 2004/108/EU / Elektromagnetisk kompatibilitet (EMC) 2004/ 108/EG.
- ☒ RoHS Directive (RoHS) 2011/65/EU / RoHS direktivet (RoHS) 2011/65/EG.
- ☒ No electromagnetic compatibility (EMC) immunity or emission tests are required on the assembly/
Produkten innehåller inte elektroniska apparater som påverkas enligt förbehållen enligt direktivet (EMC) 2004/108/EG.

The following harmonised standards (latest edition) or technical specifications which comply with good engineering practice in safety matters in force within the EU have been used in the design: /

Följande harmoniserade standarder (senaste utgåva) eller tekniska specifikationer som uppfyller god säkerhetsteknik praxis inom EG har använts i konstruktionen: SS EN 61439-3

☒ The equipment conforms completely with the above stated harmonised standards or technical specifications. /
Materielen överensstämmer helt med ovan angivna harmoniserade standarder eller tekniska specifikationer.

Or/eller

- ☐ The equipment confirms only partially with the above stated harmonised standards or technical specifications but complies with good practice in safety matters in force within the EU. /
Materielen överensstämmer endast delvis med ovan angivna harmoniserade standarder eller tekniska specifikationer, men uppfyller god säkerhetsteknik praxis inom EG.

We have product surveillance according to CENELEC's harmonised requirements, documents CCA-201.

Garö AB
Company/Företag

2018-06-14
Date/Datum

Sign/Underskrift

Environmental- and Quality Manager/Kvalitets- och Miljöchef
Position/Befattning

Magnus Arvidsson
Name / Namnförtydligande