



GLB Plus Wall Mounted Charging

Type

GLB-DC-MC- PLUS
GLB-DC-LAN-PLUS
(3G/4G Version)

AC output

Type 2 socket or Plug, Mode 3.

Rated current [A] 6,10,16,20,25,32

Power outlet [kW]
3.7KW,7.4KW,22KW

Load Balancing:

Available with optional Garo RS485 Meter. Charging power is dynamically controlled to protect main fuse of building.

MID Internal Meter: Yes

Communication: LAN or 4G capability allows user to send and receive data from the Charge Point, Schedule charging for off-peak times and export energy reports. OCPP1.5 & 1.6

Display: LED Display of status

DC Leakage Monitoring: Yes

RFID: Yes

Safety: Revert to minimum current upon loss of communication with load balancing equipment.

Over/Under Voltage protection.

Common characteristics

Rated voltage [V AC]

230/400

Frequency [Hz]

50

Temperature range [C]

-25...+40

Location

Wall mounted or GLB Stand.
Charge

Current (A) 6,10,16,20,25,32,

Degree of protection [IP]

44

Standard

EN 61851-1 IEC 61439-7 AEVCS

Width [mm]

205

Height [mm]

422

Depth [mm]

124

Netweight [kg]

3.20

Materials



Plastic

Colour

Black

Warranty

up to 3 years *with registration



MANUFACTURED
IN EUROPE



COMPREHENSIVE
WARRANTIES



80 YEARS
OF EXPERTISE

GARRO

+ 353 1 866 5360 sales@garro.ie www.garro.ie

Unit 19/ 307 Northwest Business Park, Ballycoolin, Dublin 15 D15 AV81



Dokument/document Försäkran om överensstämmelse/ Declaration of conformity		Utgåva datum/edition date 2015-05-04
Avdelning/department Kvalitet/Quality		
Ansvarig/prepared Kent Andersson	Version 4	Sida/page 1 av/of 1

Manufacturerer/Tillverkare: GARO AB
Box 203
S-335 25 GNOSJÖ
Sweden

Telephone: +46 (0)370 33 28 00
Telefax: +46 (0)370 33 28 50

Agent established within EC/Ombud etablerad inom EG

Telephone:
Telefax:

Agent of equipment/Materielslag: Home charger/Hemmaladdare

Trade Mark/Varumärke: GARO

Type Designation/Typbeteckning: GHL-...GLB-...and/och GHLM-...

**We hereby declare that our product fulfils the requirements of following EC directives/
Vi intygar härmed att vår produkt uppfyller krav enligt följande EU direktiv:**

- The Low Voltage Directive (LVD) 2014/35/EU / Lågspänningsdirektivet (LVD) 2014/35/EU.**
- Electromagnetic compatibility (EMC) 2014/30/EU / Elektromagnetisk kompatibilitet (EMC) 2014/30/EU.**
- RoHS Directive (RoHS) 2011/65/EU / RoHS direktivet (RoHS) 2011/65/EU.**
- No electromagnetic compatibility (EMC 2014/30/EU) immunity or emission tests are required on the assembly / Produkten innehåller inte elektroniska apparater som påverkas enligt förbehållen enligt direktivet (EMC) 2014/30/EU.**

**The following harmonised standards (latest edition) or technical specifications which comply with good engineering practice in safety matters in force within the EC have been used in the design:/
Följande harmoniserade standarder (senaste utgåva) eller tekniska specifikationer som uppfyller god säkerhetsteknik praxis inom EG har använts i konstruktionen: EN 61851-1, EN 62196-2 and/och IEC/TS 61439-7.**

- The equipment confirms completely with the above stated harmonised standards or technical specifications./
Materielen överensstämmer helt med ovan angivna harmoniserade standarder eller tekniska specifikationer.**

Or/Eller

- The equipment confirms only partially with the above stated harmonised standards or technical specifications but complies with good practice in safety matters in force within the EC./
Materielen överensstämmer endast delvis med ovan angivna harmoniserade standarder eller tekniska specifikationer, men uppfyller god säkerhetsteknisk praxis inom EG.**

We have product surveillance according to CENELEC's harmonised requirements, documents CCA-201.

GARO AB
Company/Företag

2017-11-24
Date/Datum

Sign/Underskrift

Responsible for Technology and standardization/Teknik och standardiseringsansvarig
Position/Befattning

Kent Andersson
Sign in printed letters/Namnförtydligande